

NEW VÅLER CHURCH

APPENDIX

AALBORG UNIVERSITY, DEPARTMENT OF ARCHITECTURE,
DESIGN & MEDIA TECHNOLOGY
MSC4, ARCHITECTURAL DESIGN, SPRING 2012

PROJECT TITLE:	NEW VÅLER CHURCH
VOLUME:	APPENDIX
PROJECT TYPE:	MASTER THESIS IN ARCHITECTURE
PROJECT THEME:	RELIGIOUS ARCHITECTURE
PROJECT PERIOD:	01.02.2012 - 29.06.2012
DATE OF SUBMISSION:	23.05.2012
COPIES	5
PAGES	33
NUMBER OF APPENDICES	3

NAMES:	CASPER LINDSKOG PEDERSEN MARIANA SOARES CARDOSO
--------	--

SUPERVISOR:	ADRIAN CARTER PROFESSOR
-------------	----------------------------

TECHNICAL CONSULTANT	PETER V. NIELSEN PROFESSOR
----------------------	-------------------------------

CASPER LINDSKOG PEDERSEN

MARIANA SOARES CARDOSO

SYNOPSIS

APPENDIX

The project is based upon an open competition which took place in the autumn of 2011, formulated by the municipality of Våler. The competition describes the design of a new church for the parish of Våler, as a result of the devastating fire which destroyed the original Church of Våler.

To support the design of the church,

theoretical investigations about Sacred Spaces, Nordic architecture and Tectonic design have been made. Furthermore, as the technical focus of the project is sustainability and energy, these themes have also been studied.

The new Våler church is designed as a low-energy building in a Scandinavian context.



TABLE OF CONTENT

APPENDIX

6 1. DRAWINGS OF THE ORIGINAL CHURCH

2. TECHNICAL CALCULATIONS

8	2.1 WIND PROFILE
	2.2 CHURCH HALL
10	- 2.2.1 PERCEIVED AIR QUALITY
12	- 2.2.2 MONTH AVERAGE
14	- 2.2.3 24-HOURS AVERAGE / VENTILATION
16	- 2.2.4 BE10 KEY NUMBERS
	2.3 FRAMING BUILDINGS
18	- 2.3.1 PERCEIVED AIR QUALITY
22	- 2.3.3 24-HOURS AVERAGE / VENTILATION
28	- 2.3.4 BE10 KEY NUMBERS
30	- 2.3.5 BSIM DOCUMENTATION



3. U-VALUE



32	3.1 VITROCSA WINDOW CALCULATION
----	---------------------------------



1. DRAWINGS OF THE OLD CHURCH

PLAN & ELEVATIONS





2. TECHNICAL CALCULATIONS

2.1. WIND PROFILE

The wind velocity profile have been calculated for suburban or forest areas, through the following equation:

$$V_h = V_g \cdot k \cdot h^\alpha$$

$$V_g = V_h / (h/h_g)^\alpha$$

$$\alpha = 0,28$$

$$V_h = 3 \text{ m/s}$$

$$V_g = 3 / (10/250)^{0,28} = 7,39 \text{ m/s}$$

In a height of 2 meters:

$$V_2 = V_g \cdot (h/h_g)^\alpha$$

$$V_2 = 7,39 \cdot (2/250)^{0,28} = 1,91 \text{ m/s}$$

This is set as the presumed wind profile to calculate the openings for natural ventilation, with the natural ventilation spreadsheet.

2. TECHNICAL CALCULATIONS

2.2.1. CHURCH HALL - PERCEIVED AIR QUALITY

THERMAL ENVIRONMENT

activity level of occupants – $M_r = 1,2$ met - sedentary activity

clothing insulation of occupants

summer:

$I_{cl} = 0,5$ clo – daily wear clothing

winter:

$I_{cl} = 0,95$ clo - daily wear clothing

optimum temperatures – category 2

summer:

$I_{cl} = 0,5$ clo

$M_r = 1,2$ met $T_s = 24^\circ\text{C} \pm 2,0^\circ\text{C}$ regulation 23 - 26°C

winter:

$I_{cl} = 0,95$ clo

$M_r = 1,2$ met $T_w = 22^\circ\text{C} \pm 1,5^\circ\text{C}$ regulation 20 – 24°C

PPD

Category 2 – PPD = < 10%

Permissible mean air velocity – category 2

turbulence intensity – 40%

summer: $v_a = 0,23$ m/s

winter: $v_a = 0,18$ m/s

Permissible vertical air temperature difference (between head and ankles)

category 2 - <3°C

Permissible range of floor temperature

category 2 – 19 to 29°C

Permissible radiant temperature assymetry

Category 2 warm ceiling <5°C

Cool wall <10°C

REQUIRED VENTILATION RATE

Comfort

$$Q_c = 10 * ((G_c + (a * A)) / (C_{ci} - C_{co}) * (1 / \epsilon_v)) \text{ [l/s]}$$

Q_c – ventilation rate required for comfort (l/s)

G_c – sensory pollution load (olf)

$C_{c,i}$ - desired perceived indoor air quality (decipol)

$C_{c,o}$ – perceived outdoor air quality (decipol)

ϵ - ventilation effectiveness

FOR CHURCH HALL

occupants – 250

area – 309 m²

sensory pollution load

sedentary occupants and no smokers – 0,81 olf / m²

Carbon dioxide - 19 l/h person

Water vapour – 50 g/h occupant

pollution load caused by the building

Non Low polluting buildings (Timber construction) – 0,2 olf / m²

$$G_c \text{ (total)} = 0,81 + 0,2 = 1,01 \text{ olf / m}^2$$

desired indoor air quality

Category 2 (20% dissatisfaction) – $C_{c,i} = 1,4$ decipol

outdoor air quality

suburban, excellent – $C_{c,o} = 0,1$ decipol

Ventilation effectiveness - ϵ

Mixing ventilation = 0,9 (worst case)

$$Q_c = 253,25 \text{ l/s} = 0,82 \text{ l/s.m}^2 = 0,32 \text{ h}^{-1}$$

Room volume of 2814 m³

2. TECHNICAL CALCULATIONS

2.2.2. CHURCH HALL - MONTH AVERAGE

Surface-area to Volume Ratio & Surface-area to Area Ratio

Shape	Height[m]	Area[m2]	Volume[m3]	Exposed Surface Area[m2]	Surface-area to Volume Ratio
Rectangular Structure					
	8	216	1727	755	0,437
	10	216	2159	890	0,412
	12	216	2590	1025	0,396
	14	216	3022	1160	0,384
Ship Structure					
	8	216	1928	762	0,395
	10	216	2000	889	0,445
	12	216	2400	1016	0,423
	14	216	2799	1143	0,408
Shell structure 0					
	8	216	1222	527	0,431
	10	216	1398	615	0,440
	12	216	1748	727	0,416
	14	216	1975	827	0,419
Shell structure 1					
	8	216	1228	534	0,435
	10	216	1525	640	0,420
	12	216	1813	744	0,410
	14	216	2136	860	0,403
Shell structure 2					
	8	216	1194	522	0,437
	10	216	1517	623	0,411
	12	216	1803	715	0,397
	14	216	2130	823	0,386
Shell structure 3					
	8	216	1186	499	0,421
	10	216	1495	592	0,396
	12	216	1785	683	0,383
	14	216	2084	777	0,373

Surface-area to Area Ratio	Air change rate (design criteria) [l/s/m ²]	Energy Consumption (Month Average) [KWh/m ² /year]
3,495	0,83	80,9 (0,0)
4,120	0,83	92,3 (0,0)
4,745	0,83	103,5 (0,0)
5,370	0,83	114,9 (0,0)
3,528	0,83	85,7(0,0)
4,116	0,83	97,9 (0,0)
4,704	0,83	110,2 (0,0)
5,292	0,83	122,8(0,0)
2,440	0,83	61,5 (0,0)
2,847	0,83	66,9 (0,0)
3,366	0,83	74,9 (0,0)
3,829	0,83	76,1 (0,0)
2,472	0,83	60,4 (0,0)
2,963	0,83	67,3 (0,0)
3,444	0,83	74,3 (0,0)
3,981	0,83	82,3 (0,0)
2,417	0,83	60,8 (0,0)
2,884	0,83	67,2 (0,0)
3,310	0,83	73,0 (0,0)
3,810	0,83	77,6 (0,0)
2,310	0,83	55,9 (0,0)
2,741	0,83	61,2 (0,0)
3,162	0,83	66,8 (0,0)
3,597	0,83	69,1 (0,0)

2. TECHNICAL CALCULATIONS

2.2.3. CHURCH HALL - 24 HOURS / VENTILATION

Church Hall

The IAQ design criteria's for the buildings is: $0,82 \text{ l/s.m}^2 = 0,32 \text{ h}^{-1}$
 area – 309,0 m² | volume – 2814 m³

In order to define the minimum opening area of the windows, many criteria's had to be decided. The following information had been used:

wind factor= 0,57
 V meteo (Wind profile) = 1,91 m/s


To analyse the natural ventilation principles, the whole building was considered as one zone. The figure represents the ventilation scheme when the predominant wind is from south. However, as the predominant wind in Våler is both from north and south directions, both facades will have inlet openings, so that natural ventilation can be provided in both conditions.

Wind pressure coefficient: inlet: facade 1 = 0,5
 outlet: roof (> 30°) = -0,8

Considering that the air extracted from the toilets (10 l/s per toilet) is provided through the inlet of the entrance and the Church Hall, the difference from inlets and outlets is $20 \text{ l/s} = 0,02 \text{ m}^3/\text{s}$.

INLETS / OUTLETS		HIGHT (m)	OPENING AREA (m ²)	AFR (m ³ /s)	AFR TOTAL (m ³ /s)
Inlets	south facade	0,1	0,18	0,284	0,284
outlets	north facade	12	0,18	-0,264	- 0,264

Difference air flow rate: $0,284 \text{ m}^3/\text{s} - 0,264 \text{ m}^3/\text{s} \rightarrow 0,02 \text{ m}^3/\text{s}$
 Volume: 2814 m³
 Total air flow rate: $0,284 \text{ m}^3/\text{s} = 0,36 \text{ h}^{-1} > 0,32 \text{ h}^{-1}$
 Location of neutral plan: 6,1 m



The total air flow rate was used in the spread sheet 24h-average to analyse the indoor climate conditions. However, in 24h-average spread sheet is not possible to take in consideration the shadow created by the shell around the glass, which creates consequently overheat during the summer months (see table below). The building is further investigated with the program Be10, which can take the angles of the shadows created by the overhang of the shell in consideration, and thereby will give a more precise result.

TEMPERATURE (°C)	ti	ti max
June	26,0	29,4
July	26,8	30,2
August	25,6	28,8

2. TECHNICAL CALCULATIONS

2.2.4. CHURCH HALL - BE10 KEY NUMBERS

The figure to the side is taken from the BE10 program. It illustrates the total energy consumption for the church hall.

In addition, the energy contribution to heat, domestic hot water, ventilation and lighting can be seen.

The full documentation of the BE10 calculations for the church hall can be seen on the attached CD.

Key numbers, kWh/m ² year			
Energy frame in BR 2010			
Without supplement	Supplement for special conditions	Total energy frame	
57,8	0,0	57,8	
Total energy requirement		160,3	
Energy frame low energy buildings 2015			
Without supplement	Supplement for special conditions	Total energy frame	
33,2	0,0	33,2	
Total energy requirement		128,4	
Energy frame Buildings 2020			
Without supplement	Supplement for special conditions	Total energy frame	
20,0	0,0	20,0	
Total energy requirement		96,3	
Contribution to energy requirement		Net requirement	
Heat	159,7	Room heating	152,1
El. for operation of building	0,3	Domestic hot water	7,5
Excessive in rooms	0,0	Cooling	0,0
Selected electricity requirements		Heat loss from installations	
Lighting	0,2	Room heating	0,0
Heating of rooms	0,0	Domestic hot water	2,3
Heating of DHW	0,0	Output from special sources	
Heat pump	0,0	Solar heat	0,0
Ventilators	0,1	Heat pump	0,0
Pumps	0,0	Solar cells	0,0
Cooling	0,0	Wind mills	0,0
Total el. consumption	0,8		

2. TECHNICAL CALCULATIONS

2.3.1. FRAMING BUILDINGS - PERCEIVED AIR QUALITY

THERMAL ENVIRONMENT

activity level of occupants – $M_r = 1,2$ met - sedentary activity

clothing insulation of occupants

summer:

$I_{cl} = 0,5$ clo – daily wear clothing

winter:

$I_{cl} = 0,95$ clo - daily wear clothing

optimum temperatures – category 2

summer:

$I_{cl} = 0,5$ clo

$M_r = 1,2$ met $T_s = 24^\circ\text{C} \pm 2,0^\circ\text{C}$ regulation 23 - 26°C

winter:

$I_{cl} = 0,95$ clo

$M_r = 1,2$ met $T_w = 22^\circ\text{C} \pm 1,5^\circ\text{C}$ regulation 20 – 24°C

PPD

Category 2 – PPD = < 10%

Permissible mean air velocity – category 2

turbulence intensity – 40%

summer: $v_a = 0,23$ m/s

winter: $v_a = 0,18$ m/s

Permissible vertical air temperature difference (between head and ankles)

category 2 - <3°C

Permissible range of floor temperature

category 2 – 19 to 29°C

Permissible radiant temperature assymetry

Category 2 warm ceiling <5°C

Cool wall <10°C

REQUIRED VENTILATION RATE

Comfort

$$Q_c = 10 * ((G_c + (a * A)) / (C_{ci} - C_{co}) * (1 / \epsilon_v)) \text{ [l/s]}$$

Q_c – ventilation rate required for comfort (l/s)

G_c – sensory pollution load (olf)

$C_{c,i}$ - desired perceived indoor air quality (decipol)

$C_{c,o}$ – perceived outdoor air quality (decipol)

ϵ - ventilation effectiveness

FOR FRAMING BUILDING - ADMINISTRATION BUILDING

occupants – 8

area – 393,5 m²

sensory pollution load

sedentary occupants and no smokers – 0,01 olf / m²

Carbon dioxide - 19 l/h person

Water vapour – 50 g/h occupant

pollution load caused by the building

Low polluting buildings – 0,1 olf / m²

$$G_c \text{ (total)} = 0,01 + 0,1 = 0,11 \text{ olf / m}^2$$

desired indoor air quality

Category 2 (20% dissatisfaction) – $C_{c,i} = 1,4$ decipol

outdoor air quality

suburban, excellent – $C_{c,o} = 0,1$ decipol

Ventilation effectiveness - ϵ

Mixing ventilation = 0,9 (worst case)

$$Q_c = 313,3 \text{ l/s} = 0,8 \text{ l/s.m}^2 = 0,96 \text{ h}^{-1}$$

Room height of 3m

2. TECHNICAL CALCULATIONS

2.3.1. FRAMING BUILDINGS - PERCEIVED AIR QUALITY

THERMAL ENVIRONMENT

activity level of occupants – $M_r = 1,2$ met - sedentary activity

clothing insulation of occupants

summer:

$I_{cl} = 0,5$ clo – daily wear clothing

winter:

$I_{cl} = 0,95$ clo - daily wear clothing

optimum temperatures – category 2

summer:

$I_{cl} = 0,5$ clo

$M_r = 1,2$ met $T_s = 24^\circ\text{C} \pm 2,0^\circ\text{C}$ regulation 23 - 26°C

winter:

$I_{cl} = 0,95$ clo

$M_r = 1,2$ met $T_w = 22^\circ\text{C} \pm 1,5^\circ\text{C}$ regulation 20 – 24°C

PPD

Category 2 – PPD = < 10%

Permissible mean air velocity – category 2

turbulence intensity – 40%

summer: $v_a = 0,23$ m/s

winter: $v_a = 0,18$ m/s

Permissible vertical air temperature difference (between head and ankles)

category 2 - <3°C

Permissible range of floor temperature

category 2 – 19 to 29°C

Permissible radiant temperature assymetry

Category 2 warm ceiling <5°C

Cool wall <10°C

REQUIRED VENTILATION RATE

Comfort

$$Q_c = 10 * ((G_c + (a * A)) / (C_{ci} - C_{co}) * (1 / \epsilon_v)) \text{ [l/s]}$$

Q_c – ventilation rate required for comfort (l/s)

G_c – sensory pollution load (olf)

$C_{c,i}$ - desired perceived indoor air quality (decipol)

$C_{c,o}$ – perceived outdoor air quality (decipol)

ϵ - ventilation effectiveness

FOR FRAMING BUILDING - MORTUARY BUILDING

occupants – 2

area – 290,4 m²

sensory pollution load

sedentary occupants and no smokers – 0,01 olf / m²

Carbon dioxide - 19 l/h person

Water vapour – 50 g/h occupant

pollution load caused by the building

Low polluting buildings – 0,1 olf / m²

$$G_c \text{ (total)} = 0,01 + 0,1 = 0,11 \text{ olf / m}^2$$

desired indoor air quality

Category 2 (20% dissatisfaction) – $C_{c,i} = 1,4$ decipol

outdoor air quality

suburban, excellent – $C_{c,o} = 0,1$ decipol

Ventilation effectiveness - ϵ

Mixing ventilation = 0,9 (worst case)

$$Q_c = 231,3 \text{ l/s} = 0,8 \text{ l/s.m}^2 = 0,96 \text{ h}^{-1}$$

Room height of 3m

2. TECHNICAL CALCULATIONS

2.3.3. FRAMING BUILDINGS - 24 HOURS / VENTILATION

Framing building

The total airflow rate from the openings should provide sufficient airflow to fulfil the defined air change rate. The IAQ design criteria's for the different buildings is:

Framing Building 1: $0,8 \text{ l/s.m}^2 = 0,96 \text{ h}^{-1}$
area – 393,5 m² | volume – 1180,5 m³

Framing Building 2: $0,8 \text{ l/s.m}^2 = 0,96 \text{ h}^{-1}$
area – 290,4 m² | volume – 871,2 m³

In order to define the minimum opening area of the windows, many criteria's had to be decided. The following information had been used:

wind factor= 0,57

V meteo (Wind profile) = 1,91 m/s

Framing building - Administration building


To analyse the natural ventilation principles, the building was divided into 3 different zones. The figure represents the ventilation scheme when the predominant wind is from south. However, as the predominant wind in Våler is both from north and south directions, both facades will have inlet and outlet openings, so that natural ventilation can be provided in both conditions.

ZONE 1:

Zone 1 is constituted by the entrance, the two first offices, wardrobe, toilets and small storage. In this zone the used ventilation principle is cross ventilation.

Wind pressure coefficient: inlet: facade 1 = 0,06
outlet: facade 2 = -0,3
roof (< 10) = -0,49

Considering that the air extracted from the toilets (10 l/s per toilet) is provided through the inlet of the entrance and the offices, the difference from inlet and outlet in zone 1 is $20 \text{ l/s} = 0,02 \text{ m}^3/\text{s}$



INLETS / OUTLETS		HEIGHT (m)	OPENING AREA (m ²)	AFR (m ³ /s)	AFR TOTAL (m ³ /s)
Inlets	south facade office	0	0,12	0,115	0,230
	south facade entrance	0	0,12	0,115	
outlets	north facade office	3	0,2	-0,105	- 0,210
	north facade entrance	3	0,2	-0,105	

Difference air flow rate: 0,230 m³/s - 0,210 m³/s → 0,02 m³/s
 Volume of zone1: 250,8 m³
 Total air flow rate: 0,230 m³/s = 3,3 h⁻¹ > 0,96 h⁻¹
 Location of neutral plan: 2,2 m

The total air flow rate was used in the spread sheet 24h-average to analyse the indoor climate conditions for zone 1. The follow table shows the temperatures for the worst months of the year concerning overheating, considering the use of light internal shading and windows of 2layer-pane with regular glass.

TEMPERATURE (°C)	ti	ti max
June	23,3	25,2
July	24,1	26,0
August	23,6	25,6

In July the temperature is equal to the max. of 26°C and thereby further investigations will be made with Bsim. However, the analyse was made with the weather data of Copenhagen which has an avarage temperature lightly higher than Våler, Norway, reason which could justify the need for an high air flow rate to avoid overheating. Furthermore the use of trees for shadow in the patios was not taken in consideration.

3. TECHNICAL CALCULATIONS

23.3. FRAMING BUILDINGS - 24 HOURS / VENTILATION

ZONE 2:

Zone 2 is constituted by the rest of the offices, a meeting room, toilets, small kitchen and laundry. In zone 2 the ventilation principle used is cross ventilation, which the openings have been dimensioned for. However, single sided ventilation is also possible, depending of the use of the room and the predominant wind.

Wind pressure coefficient: inlet: facade 1 = 0,06
 outlet: facade 2 = -0,3
 roof (< 10) = -0,49

Considering that the air extracted from the toilets (10 l/s per toilet), the kitchenette (10l/s) and the laundry (20 l/s) is provided through the inlet of the offices and meeting room, the difference from inlet and outlet in zone 1 is 50 l/s = 0,05 m³/s

INLETS / OUTLETS		HEIGHT (m)	OPENING AREA (m ²)	AFR (m ³ /s)	AFR TOTAL (m ³ /s)
Inlets	south facade office	0	0,11	0,109	0,327
	south facade meeting room	0	0,11	0,109	
	south facade lunch-room	0	0,11	0,109	
outlets	north facade office 1	3	0,2	-0,092	-0,276
	north facade office 2	3	0,2	-0,092	
	north facade office 3	3	0,2	-0,092	

Total air flow rate: 0,327 m³/s - 0,276 m³/s → 0,051 m³/s
Volume of zone1: 635,4 m³
Total air flow rate: 0,327 m³/s = 1,85 h⁻¹ > 0,96 h⁻¹
< 4,0 h⁻¹ (draft)
Location of neutral plan: 2,3 m

The total air flow rate was used in the spread sheet 24h-average to analyse the indoor climate conditions for zone 2. The follow table shows the temperatures for the worst months of the year concerning overheating, considering the use of light internal shading and windows of 2layer-pane with regular glass.

TEMPERATURE [°C]	ti	ti max
June	23,3	24,7
July	24,1	25,5
August	23,4	24,7

2. TECHNICAL CALCULATIONS

2.3.3. FRAMING BUILDINGS - 24 HOURS / VENTILATION

ZONE 3:

Zone 3 is constituted by a storage and technical room, using as ventilation principle cross ventilation.


Wind pressure coefficient: inlet: facade 1 = 0,06
 outlet: facade 2 = -0,3
 roof (< 10) = -0,49

INLETS / OUTLETS		HEIGHT (m)	OPENING AREA (m ²)	AFR (m ³ /s)	AFR TOTAL (m ³ /s)
Inlets	south facade storage	0	0,03	0,028	0,056
	south facade technical room	0	0,03	0,028	
outlets	north facade storage	3	0,05	-0,028	- 0,056
	north facade technical room	3	0,05	-0,028	

Volume of zone1: 208,5 m³
 Total air flow rate: 0,056 m³/s = 0,96 h⁻¹ > 0,96 h⁻¹
 Location of neutral plan: 2,2 m

The total air flow rate used for zone 3 is the minimum according to the Norwegian regulations, since the room will not be permanently used. The total air flow rate was used in the spread sheet 24h-average to analyse the indoor climate conditions, which can be seen in the follow table.

TEMPERATURE (°C)	ti	ti max
June	24,1	24,9
July	24,9	25,7
August	24,7	25,6



Framing building 2

This building is divided in two zones. The first zone is constituted by the chapel which make use of natural ventilation, while the mortuary functions, due to its different temperature and ventilation requirements, will constitute together with the storage a different zone, supplied by mechanical ventilation.

ZONE 1:

Wind pressure coeficiente: inlet: facade 4 = -0,3
 outlet: facade 1 = -0,3
 roof (< 10) = -0,49

It is consider that facade 1 will have negative pressure as it is facing a small patio and, thereby will not receive direct wind.

INLETS / OUTLETS		HEIGHT (m)	OPENING AREA (m ²)	AFR (m ³ /s)	AFR TOTAL (m ³ /s)
Inlets	east facade chapel	0	0,18	0,14	0,14
outlets	south facade chapel	3	0,3	-0,14	-0,14

Volume of zone1: 234,9 m3
 Total air flow rate: 0,14 m3/s = 2,14h⁻¹ > 0,96 h⁻¹
 Location of neutral plan: 2,3 m

TEMPERATURE (°C)	ti	max
June	23,2	25,1
July	24,0	25,9
August	23,4	25,1

2. TECHNICAL CALCULATIONS

2.3.4. FRAMING BUILDINGS - BE10 KEY NUMBERS

The figure is taken from the BE10 program. It illustrates the total energy consumption for the Administration building.

In addition, the energy contribution to heat, domestic hot water, ventilation and lighting can be seen.

The full documentation of the BE10 calculation for the administration building can be seen on the attached CD.

Key numbers, kWh/m ² year			
Energy frame in BR 2010			
Without supplement	Supplement for special conditions	Total energy frame	
56,0	0,0	56,0	
Total energy requirement		39,7	
Energy frame low energy buildings 2015			
Without supplement	Supplement for special conditions	Total energy frame	
32,1	0,0	32,1	
Total energy requirement		31,9	
Energy frame Buildings 2020			
Without supplement	Supplement for special conditions	Total energy frame	
20,0	0,0	20,0	
Total energy requirement		23,9	
Contribution to energy requirement		Net requirement	
Heat	39,4	Room heating	32,7
El. for operation of bulding	0,1	Domestic hot water	6,7
Excessive in rooms	0,0	Cooling	0,0
Selected electricity requirements		Heat loss from installations	
Lighting	5,1	Room heating	0,0
Heating of rooms	0,0	Domestic hot water	1,5
Heating of DHW	0,0	Output from special sources	
Heat pump	0,0	Solar heat	0,0
Ventilators	0,0	Heat pump	0,0
Pumps	0,0	Solar cells	0,0
Cooling	0,0	Wind mills	0,0
Total el. consumption	11,7		

The figure is taken from the BE10 program. It illustrates the total energy consumption for the Mortuary building. In addition, the energy contribution to heat, domestic hot water, ventilation and lighting can be seen.

The full documentation of the BE10 calculation for the mortuary functions building can be seen on the attached CD.

Key numbers, kWh/m ² year			
Energy frame in BR 2010			
Without supplement	Supplement for special conditions	Total energy frame	
57,7	0,0	57,7	
Total energy requirement		58,9	
Energy frame low energy buildings 2015			
Without supplement	Supplement for special conditions	Total energy frame	
33,2	0,0	33,2	
Total energy requirement		47,4	
Energy frame Buildings 2020			
Without supplement	Supplement for special conditions	Total energy frame	
20,0	0,0	20,0	
Total energy requirement		35,5	
Contribution to energy requirement		Net requirement	
Heat	57,1	Room heating	49,6
El. for operation of bulding	0,7	Domestic hot water	7,5
Excessive in rooms	0,0	Cooling	0,0
Selected electricity requirements		Heat loss from installations	
Lighting	2,7	Room heating	0,0
Heating of rooms	0,0	Domestic hot water	2,2
Heating of DHW	0,0	Output from special sources	
Heat pump	0,0	Solar heat	0,0
Ventilators	0,5	Heat pump	0,0
Pumps	0,0	Solar cells	0,0
Cooling	0,0	Wind mills	0,0
Total el. consumption	3,4		

2. TECHNICAL CALCULATIONS

2.3.5. FRAMING BUILDINGS - BSIM DOCUMENTATION

The indoor climatic conditions of the framing building have been examined in the 24 hours spreadsheet, showing that zone 1 is the most problematic area of the building concerning overheating. Therefore, it has been chosen to further examine the conditions of the indoor climatic conditions of this zone, through the documentation and simulation program BSIM.

Zone 1

Zone 1 is very exposed to solar radiation through the highly glazed south facade. Therefore will receive a great amount of passive solar gains, giving the possibility to accumulate a great amount of heat in the heavy constructions. Thus it is considered crucial to further evaluate this zone to make sure that is within the requirements of the Norwegian legislations.

The purposes of this simulation is to define the expected thermal indoor conditions of Zone 1.

Zone 1 consists of an entrance Hall, two offices and a core, which contains a wardrobe and toilets, as shown on Plan I. The geometrical model created in BSIM, has been slightly simplified to make sure that BSIM performs the most precise calculations. The Zone 1 is build as one thermal zone, and within the same thermal

zone the hallway is created as another room. As a part of the simplifications, it has been chosen not to model the interior walls in the zone.


The Zone 2 is modelled as different building, as it does not influence directly the thermal indoor climate in Zone 1, but will provide shadows for it.

Pre-conditions

The building is oriented with a rotation of 12,85 degrees to west in relation to true north.

Each of the construction parts of the building, walls, terrain deck and roof have been modelled from the BSIM database, with the U-values that can be found in the attached CD.

The windows of the building are modelled as Vitrocsa windows, with three-layer glazing units, and can be found in Appendix 3.1. The windows towards south and north (in the offices) are provided with perforated solar screens. The openness of the screens have been tested with the BSIM simulation, for a percentage of 50%, 67% and 75%. Through the test it was shown that the screens with a openness of 50% provide optimum shading, bringing the number of hours of overheating down on 36 hours, and thereby



I - PLAN OF ZONE 1 & ZONE 2

less than the 50 hours required from the Norwegian regulations. The copper solar screens are placed on the exterior of the windows, and will be installed in tracks where they can be controlled automatically or individually if desired.

In the BSIM simulation, the shadows from the shading devices were simulated through the creation of two equal sized windows, constituting together the total area of windows. One of them was set without shutter, while the second was set with shutter, thereby simulating the openness of 50% of the copper screens. The shutter is set active when the indoor operative comfort temperature rises more than 23 degrees.

The ventilation is defined as calculated with the natural ventilation spreadsheet, with the opening towards south placed in the floor and the openings towards north located in the top of the windows.

Systems

People load: The people load of zone 1 is defined by the presence of two persons that work in the two offices placed at the entrance of the building. The schedule for people load is defined within the normal working hours.

Equipment: The equipment is defined as computer equipment, with a heat load

equal to 100W per Person.

Artificial light: The artificial lighting is defined by 8W/m² for the ceiling lighting and 1 asymmetric architect lamp with low energy bulb per Person.

Infiltration: The infiltration is set with a basic air change of 0.3h⁻¹.

Heating: The heating system is defined as radiators / convectors which are set as active all year, except in the summer. It has been chosen to use radiators / convectors as it is easier to adjust for the indoor climate, as floor heat has a slower reaction time. The heating is put to active at a set point of 22 degrees.

Mechanic ventilation: The mechanic ventilation is active during the entire year, except from the week 20 to the week 38, where the natural ventilation will provide the sufficient air change. The basic air change is equal to the IAQ design criteria defined by the step-by-step method in CR1752, and is given as 0,01 m³/s.

The ventilation is designed with a heat recover system with a maximum heat recover coefficient of 0,8, making it possible to take use of the recover of the inlet air, which can reduce the requirements of heating.

The mechanic ventilation system is designed as a VAV-system, which is possible to adjust in case of change of loads. The set point for the air temperature is set to 22 degrees and the minimum inlet temperature to 16 degrees.

Venting: The natural ventilation is set to be active in the summer period, which in this case has been defined from week 21 to week 38. The basic air change is defined as 3h⁻¹, with a maximum air change rate at 5h⁻¹. The calculation method is defined by BSIM, and is given as Combined Two Levels. The set point for the natural ventilation control is put to 22 degrees.

3. U-VALUES

3.1. VITROCSA FRAME

The calculation of the total u-value of the Vitrocsa Window Frame and the 3-layer Energy Glazing, Window Type 4-18-4-18-4, Energy/Clear/Energy can be seen below.

The values of the Glazing are given as:

U_g Value = 1

G_g = 0,53

LT_g = 0,78

The total u-value of the frame and the glazing can be calculated from following formula:

$$U = A_g U_g + l_g \Psi_g + A_f U_f + l_k \Psi_k$$

Where,

A_g is glazing part in m²


A_f is area of the frame

l_g is the circumference of the glazing part

Ψ_g is the linear transmittance coefficient

$$U = (0,962 \times 0,53) + (3,856 \times 0,05) + (0,038 \times 0,28) = 0,71 \text{ W/m}^2\text{K}$$

This u-value have been used in the BE10 and BSIM calculations.



1 - DETAIL OF A TH+ VITROCSA PROFILE,
USED IN THE VERTICAL ELEMENTS OF THE
CHURCH HALL

